



No.DJB/QCLTYR/PD/260701


DELHI JAL BOARD
(GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
TRANS YAMUNA REGION TAHIRPUR DELHI-110093



Licence No- CRO/QM/L-8004274-1 as per IS/ISO 9001:2015

ACWA-TYR

Diary No. 950 dt 10/7/26



एक कदम स्वच्छता की ओर

NO: DJB/ACWA(TYR)/2026.....

DATE:- 08.07.2026

Analysis report of water samples collected from (1) Inlet (DJB supply), (2) Outlet of SNEH INTERNATIONAL SCHOOL, NEW RAJDHANI ENCLAVE, VIKAS MARG, DELHI-110092 for drinking purpose.

Ref. No. – SIS/2026-27/2087,
Challan No: - 93,

dated: - 29.06.2026
dated: - 04.07.2026

Date of collection: 06.07.2026

S. No.	PARTICULARS	BIS:10500-2012 LIMITS		UNITS	RESULT	
		Desirable	Permissible		(1)	(2)
A.	Physical Examination					
1.	Colour	...	...	-	CLEAR	CLEAR
2.	Odour	...	...	-	CHLOR.	CHLOR.
3.	Turbidity	1.0	5.0	NTU	2.58	3.90
4.	pH Value	6.5-8.5	--	-	7.6	7.5
5.	Electrical Conductivity	--	--	µs/cm	185	224
6.	Total Dissolved Solids	500	2000	mg/l	120	146
B.	Chemical Examination					
7.	P th Alkalinity	...	...	mg/l	NIL	NIL
8.	Total Alkalinity	200	600	mg/l	64	64
9.	Total Hardness	200	600	mg/l	82	88
10.	Calcium as (Ca)	75	200	mg/l	24.8	25.6
11.	Magnesium as (Mg)	30	100	mg/l	4.80	5.76
12.	Ammonical Nitrogen	0.5	NR	mg/l	N.D	N.D
13.	Nitrite			mg/l	N.D	N.D
14.	Nitrate	45	NR	mg/l	1.38	1.64
15.	Sulphate	200	400	mg/l	29.84	30.15
16.	Chloride	250	1000	mg/l	16	18
17.	Fluoride	1.0	1.5	mg/l	0.05	0.04
18.	Dissolved Iron	1.0	NR	mg/l	0.10	0.12
19.	Cyanide	0.05	NR	mg/l	N.D	N.D
20.	Residual Chlorine	0.2	1.0	mg/l	1.0	0.70
C.	Bacteriological Examination					
21.	Coliform count	Absent	NR	MPN/100ml	0	0

REMARKS:- On the basis of above tested parameters, both water samples conform to the prescribed limits and can be considered fit for drinking purpose.

(B. Sheikh Lal)
ACWA(TYR)

(A.G. Susmitha)
BACTERIOLOGIST

(Gulesh Jainar)
CHEMIST

(Mayank Yadav)
A/CHEMIST

Asstt. Chief Water Analyst

Delhi Jal Board, Govt. of N.C.T. of Delhi
Quality Control Zonal Laboratory (TYR)
Tahirpur Dillshad Garden, Delhi-110093

Komal

